

# Thermographic Inspection of Substation Transformers

Philip M. Conte, Sr. Test Engineer (retired)  
and  
George Arthur, Asset Reliability Engineer


PSEG Laboratory and Testing Services  
40 Cragwood Road  
South Plainfield, NJ 07080

www.pseg.com  
email: philmconte@gmail.com

## Abstract

When reporting thermal anomalies on exposed electrical components, data such as location, date, ambient conditions, temperature rise and load are usually recorded. But, when inspecting oil cooled substation transformers there are other key pieces of information that should be included in the report. This information will help system engineers diagnose the cause of the thermal anomaly, order specific parts and easily derive the action required to normalize cooling or conservatively de-rate the asset in terms of load carrying capability until the repair can be completed or a replacement can be installed.

This presentation will go over some common thermal anomalies to look for and data that should be recorded and where to find it when inspecting large oil cooled transformers. It will also touch on how to automatically import nameplate data from a database into your report to save time and data space by avoiding redundant information.




Healthy Transformer

## Cooling System Problems

Low oil or blocked cooling fins (radiators) can compromise the cooling system of a transformer and cause it to overheat. If the oil level gets low enough to expose the core and coil of a transformer gassing occurs. The combination of heat and gassing can lead to pressure build up that can have disastrous consequences.

Look for the cooling fins to be within 10°C of the main tank with about a 10°C gradient from top to bottom.



### Cooling System Failure Avoidance / Saves Due to IR Scan



- Substation Supervisor: “We added oil to T-1 in Ridgewood yesterday (1-31-2017). We opened the top hatch and found that the oil level was just below the radiators. Added roughly 80 gallons of oil and made sure that now the oil level was above radiators. Now we can have another thermographic inspection done.” Transformer Expert - Electric & Gas Asset Strategy: “Sounds like we saved a transformer – extreme failure and possibly loss of life.”
- “Arcola T-2 IR survey indicates transformer oil level low (April, 2013) – Add 1-½ drum of oil, performed DGA (Dissolved Gas Analysis) test and infrared radiators after energizing the following day. Temperature of the entire unit including the radiators returned to normal. This action enhances the life of the transformer by improving cooling and avoids the transformer from gassing due to end result in possible core and coil exposure.”

Example of one that was lost:



# LTC Problems

Look for the Load Tap Changer to be no warmer than the main tank.




## LTC Failure Avoidance / Savings Due to IR Scan

- "Polk St. #3 Transformer - Drain and inspect OLTC, found oil highly carbonized and sludge. Rust in OLTC compartment from water seepage from cap on top of OLTC. Repair leaks, paint rusted section; wipe and wash clean OLTC of sludge. Refill OLTC with new oil. These actions have enhanced the life of the transformer. Action was due to IR scan results."






- “Centex Towers Unit Sub 300 - Drain and inspect OLTC, found heavy oil sludge and low oil level. Wash OLTC clean of sludge and replace oil with new to the correct level. This action has enhanced the life of the transformer. Action was due to IR scan results.”



- “Marlton T2 LTC – Oil was changed and contacts were cleaned. Action was due to IR scan results and DGA readings.”

## Bushings



The problem here is the bolted connection at the top of the bushing, but the high heat may have damaged the entire bushing so it was determined to replace it. In this case, at least, the manufacturer and serial number of the transformer should be recorded.

### Data to Record

- 1) **Manufacturer** - Knowing the manufacturer of the asset/equipment helps system engineers to tactically group the component with the problem. They can then connect the trending history with the manufacturer's component to make strategic decisions. For example, what damages are likely to occur and spare parts needed to correct the problem for a specific trademark, avoid problems from repeating – knowing the underperformance of the product, replace as a whole and or discontinue the equipment purchase, etc.
- 2) **Serial number** – To trend a specific transformer and look up the specifics for that model.
- 3) **Cooling Class** - The byproduct of losses generated in a transformer is heat. The heat is dissipated via the cooling system. The design of the cooling system is identified by the cooling class. There are usually three or more cooling configurations listed on the name plate such as "ONAN/ONAF1/ONAF2". Knowing the cooling class and the thermal performance of the asset – you can easily derive the action required to normalize cooling or conservatively de-rate the asset in terms of load carrying capability for any abnormality observed in the restriction of the intended cooling.

- 4) **Highest KVA @ 65°C Rise** – Under the Cooling Class there is a KVA value listed which corresponds to each of the cooling configurations such as 27000/36000/45000 followed by “KVA 65°C Rise”. This is the operating temperature spec for the transformer. The thermal performance of a transformer is associated with its load carrying capability. If the load increases the transformer temperature will increase because of the I<sup>2</sup>R loss. Therefore, there is a correlation between the operating load in KVA and the transformer winding/top oil temperatures. If the temperature gauges are indicating higher temperatures with respect to the current KVA reading there is a problem with the transformer cooling initiating further investigation to correct the cooling problem or de-rate the transformer.

(These four pieces of information are obtained from the Name Plate. Alternatively, if the utility has a Computerized Maintenance Management System (CMMS) with name plate data in a table and you are using a database such as InspecTrend, Exception Pro or MS Access, you can simply use the serial number to import the other three pieces of data.)

**LESS THAN 1 PPM OF MANUFACTURE**

**SHIPPED WITH DRY AIR**  
FIELD OR BURN ON TANK.  
MINIMUM OXYGEN BEFORE  
THIS DECAL AND FILL BEFORE ENERGIZING.  
INSTRUCTION BOOK FOR  
Pennsylvania Transformer Technology, Inc. 673014010

**LELTS 3 UN/AIN/UNAF/UNAF**  
FULL LOAD CONTINUOUSLY  
27000/36000/45000 kVA 65°C RISE  
230000-13800GndY/7967 VOLTS

APPROXIMATE WEIGHT IN POUNDS  
CORE AND COILS (HEAVIEST PIECE) --- 125,500  
TANK AND FITTINGS --- 44,930  
TYPE RW 4 LIT. MECHANISM AND REFORMER COMPARTMENT --- 2,660  
DEFORMABLE RADATORS --- 22,320  
CONSERVATOR & SUPPORTS --- 5,900  
US030 12,410 GALLONS IN --- 93,075  
US040 345 GALLONS LIT. COMPARTMENT --- 2,590  
US050 760 GALLONS IN --- 5,700  
US060 586 GALLONS IN --- 4,395  
TOTAL WEIGHT --- 307,070  
UNLIFTING WEIGHT --- 125,500  
SHIPPING WEIGHT --- 168,590  
GALLONS OF OIL IN MAIN TANK TO COVER CORE & COILS --- 9,635

PHASOR DIAGRAM

FULL WAVE IMPULSE LEVEL  
HIGH VOLTAGE --- 750 KV  
HV BUSBAR --- 800 KV  
LOW VOLTAGE --- 110 KV  
LV W/ NEUTRAL --- 110 KV  
LV BUSBAR --- 150 KV  
RV BUSBAR --- 150 KV

WINDING MATERIAL  
HIGH VOLTAGE --- COPPER  
LOW VOLTAGE --- COPPER

SHIPPING DIMENSIONS  
L = 201.000"  
W = 132.000"  
H = 148.500"

READ INSTRUCTION BOOK BEFORE INSTALLING OR OPERATING

14, 13 A POSITIVE SEQUENCE IMPEDANCE 23000-13800GndY/7967 VOLTS AT 27000 KVA  
14, 6 B ZERO SEQUENCE IMPEDANCE 23000-13800GndY/7967 VOLTS AT 27000 KVA

LIQUID LEVEL BELOW TOP SURFACE OF HIGHEST POINT OF CONSERVATOR BREAKER FLANGE AT 25°C 46,000 INCHES  
SEE INSTRUCTION BOOK FOR VALUE AT TEMPERATURE EXTREMES.  
LIQUID LEVEL CHANGE PER 10°C LIQUID TEMPERATURE CHANGE 2,750 INCHES

READ INSTRUCTION BOOK BEFORE INSTALLING OR OPERATING  
MAXIMUM OPERATING PRESSURE OF LIQUID PRESERVATION SYSTEM 0 PSI POSITIVE TO 2 PSI POSITIVE  
MAIN TANK, CONSERVATOR TANK & LIT. COMPARTMENT ARE DESIGNED FOR POSITIVE 15 PSI AND FULL VACUUM  
SEE INSTRUCTION BULLETIN T-01 FOR DETAILED INFORMATION REGARDING VACUUM PROCESSING  
SEE INSTRUCTIONS FOR PARTS OF OTHER PARTS  
THE INSULATING LIQUID IN THIS EQUIPMENT CONTAINS NO PEROXIDES AT DATE OF MANUFACTURE.

POSITION	CONNECTS ON EACH PHASE	VOLTS	AMPS AT MAXIMUM RATING
1	12 TO 13	241500	108
2	13 TO 14	222500	110
3	14 TO 15	203000	113
4	15 TO 16	242500	116
5	16 TO 17	218500	119


POSITION	CONNECTS ON EACH PHASE	LOW VOLTAGE	AMPS AT MAXIMUM RATING
1	12 TO 13	10875	108
2	13 TO 14	11880	110
3	14 TO 15	12884	113
4	15 TO 16	14888	116
5	16 TO 17	16892	119

**CURRENT TRANSFORMERS**  
M 402 201 --- 1200-5 AMPERES MULTI-RATIO, C-ROD, CURVE REF-243485-8C  
M 403 201 --- 2000-5 AMPERES MULTI-RATIO, C-ROD, CURVE REF-495333-8C  
M 404 201 --- 1200-5 AMPERES MULTI-RATIO, C-ROD, CURVE REF-243485-8C  
M 405 201 --- 2000-5 AMPERES MULTI-RATIO, C-ROD, CURVE REF-495333-8C  
M 406 201 --- 1200-5 AMPERES MULTI-RATIO, C-ROD, CURVE REF-243485-8C  
M 407 201 --- 2000-5 AMPERES MULTI-RATIO, C-ROD, CURVE REF-495333-8C  
M 408 201 --- 1200-5 AMPERES MULTI-RATIO, C-ROD, CURVE REF-243485-8C  
M 409 201 --- 2000-5 AMPERES MULTI-RATIO, C-ROD, CURVE REF-495333-8C

PLAN VIEW PHASOR LOW VOLTAGE



- 5) **Tap Changer Position** – If there is a hot LTC, the problem may be associated with a particular tap.



- 6) The **LTC operating count** helps system engineers to determine several things:
- a) Knowing the volume of gases generated, the LTC operations count helps to decipher the gases generated due to normal arcing from LTC switching versus coking of the contacts if no voltage correction was demanded by the system and no progression in the count occurred.
  - b) Wear and tear of the fixed and movable contacts - The number of the operating count determines when the LTC contacts need to be changed or serviced.
  - c) Too much operation of the LTC count will require addressing the bandwidth of the LTC voltage setting or investigating external equipment like the bus PT, cap-bank, large power customers' consumption, etc.



- 7) As explained earlier, **oil and winding temperatures** are determined by the load and the thermal performance of the transformer. If the load increases, these temperatures will increase based on the cooling class capability. Knowing the current KVA value, the atmospheric temperature and the oil and winding temperatures will communicate the cooling performance of the transformer. Any oil and winding temperatures above the correlated KVA and existing atmospheric temperature will tell us that the transformer has a cooling deficiency and further investigation is required to identify the problem.



- 8) **Oil Level** is critical to cooling and avoids gassing due to core and coil exposure. The Oil Level gauge reading helps determine whether a cold radiator is due to low oil or a blockage. There may also be Oil Level and Oil Temp gauges for an LTC which should be recorded as well. The middle of the Oil or Liquid Level gauge shows what the level should be when the oil is 25°C.





# Recording the Data

Date E-Mailed: \_\_\_\_\_

## TRANSFORMER INSPECTION Field Data Sheet

Date	2-21-17		
Time	10:19		
Pic# Thermal/Visual	1/8958		
Station	Homestead		
Transformer	NO. 1		
Serial #	G2930-02		
Winding Temp	21°C		
Oil Temp	21°C		
Taylor Temp			
Oil Level	>25		
Tap Changer Postion	3L		
Tap Changer Count	5979		
Tap Changer Temp	18°C		
Tap Changer Level	25		
Component	LTC		
Direction	N		
Load	630		
Rated Load	935		
Temp Rise	3°C		
Ref Temp	17°C		
Weather	Sunny		
Amb. Temp	42°F		
<b>For New Transformers</b>			
Manufacturer			
Class			
kVa @ 65 Deg C			
Comments			

Completed By: \_\_\_\_\_



---

---

# PSEG LABORATORY & TESTING SERVICES

Thermographic Inspection - Procedure MTL-2 Rev. 6

IR Inspection of Transformers for Palisades Division

---

---

Date Surveyed: 1/30/2017    Work Order:  
Time: 14:35    101002959  
Station: Ridgefield 230-13Kv  
Transformer: # 10 Transformer  
Location: Load Tap Changer

### Transformer Information

Manufacturer: PENNSYLVANIA  
S/N C0771553    KV: 230-13  
Class: OA/FA/FA  
kVA @65C Rise 27000.00

### Main Tank

Taylor Temp: 20°C    Oil Temp: 20°C  
Winding Temp: 23°C    Oil Level: <25C

### LTC

Position: 7    Count: 5467  
Oil Temp: 17°C    Oil Level: >25C


### Conditions Found

Component: Tap Changer  
Description:

Direction: Facing South  
Load: 776 Amps  
Rated Load: 1969 Amps  
Temp Rise: 10°C (above reference)  
Ref Temp: 12°C (adjacent component)  
Weather: Partly Sunny and 41°F  
Comments:



Photograph of Component



Thermograph of Component

Category: LTC 10°C+  
Priority: 1, Repair as soon as possible

Client: Matt McCue - Sr Distribution Spv  
IR Camera: 170879 cal due 05/27/17  
Evaluated By: Phil Conte, ANSI Level III  
Thermographer: Phil Conte, ANSI Level III  
Mechanical Division (973)390-0303

**Transformer:** # 10 Transformer

**Location:** Load Tap Changer

**Transformer Information**

**Manufacturer:** PENNSYLVANIA

**S/N** C0771553                      **KV:** 230-13

**Class:** OA/FA/FA

**kVA @65C Rise** 27000.00

**Main Tank**

**Taylor Temp:** 20°C              **Oil Temp:** 20°C

**Winding Temp:** 23°C      **Oil Level:** <25C

**LTC**


**Position:** 7L                      **Count:** 5467

**Oil Temp:** 17°C      **Oil Level:** >25C


**Conditions Found**

**Component:** Tap Changer

**Description:**



Phot



## Conclusion

Recording a few extra pieces of information makes a report much more useful to system engineers in determining a course of action.